

SECTION 13865B

APPENDIX B - FLOW METERS FLOW METERS INDEX

APPENDIX B INDEX	13865B-1
ELECTROMAGNETIC FLOW METER: TYPE EMFM-1 SPECIFICATION	13865B-2
AVERAGING PITOT TUBE FLOW METER TYPE APFM-1 SPECIFICATION	13865B-3
THERMAL DISPERSION FLOW METER TYPE TDFM-1	13865B-4

GENERAL FLOW METER TECHNICAL SPECIFICATION SHEET

FLOW METER TYPE: ELECTROMAGNETIC (TYPE EMFM-1)

SEE THE FLOW METER SCHEDULE FOR SPECIFIC TECHNICAL REQUIREMENTS.

1. GENERAL:	
PROVIDE AN ELECTROMAGNETIC FLOW METER ASSEMBLY COMPLETE WITH ALL AUXILIARY DEVICES, WHICH MEETS ALL OF THE SERVICE CONDITIONS, FLOW PARAMETERS AND CALIBRATION REQUIREMENTS AS INDICATED. THE FLOW METER ASSEMBLY MATERIALS OF CONSTRUCTION SHALL BE FULLY COMPATIBLE WITH THE PROCESS FLUIDS AND THE AMBIENT CONDITIONS. PROVIDE A COMPLETE SPECIFICATION SHEET FOR EACH METER.	
2. TECHNICAL:	
CONSTRUCTION:	WATERTIGHT, GENERAL USE
PROCESS FLUID:	AS SCHEDULED
METER TYPE:	ELECTROMAGNETIC
PROCESS LINE SIZE:	AS SCHEDULED
NOMINAL METER SIZE:	AS SCHEDULED
METER END CONNECTIONS:	FLANGED OR AS SCHEDULED
ANSI BODY RATING:	ANSI CLASS 150
BODY MATERIAL:	STAINLESS STEEL (SUS 304)
BODY LINER:	TEFLON PFA OR PFTE
ELECTRODE MATERIAL:	STAINLESS STEEL (SUS 316L)
EARTH RING:	STAINLESS STEEL (SUS 316)
MAXIMUM ALLOWABLE METER PERMANENT PRESSURE DROP:	0.1 PSI AT MAXIMUM DESIGN FLOW
ACCURACY:	+/- 0.5% OF RATE
TRANSMITTER OUTPUT SIGNAL:	4 TO 20 mADC ANALOG RATE
FLOW METER CALIBRATION RANGE:	AS SCHEDULED
FLOW METER POWER REQUIREMENTS:	120 VAC / 10 / 60 Hz.
CONVERTOR:	SELF-CONTAINED AT METER
LOCAL ANALOG METER:	NOT REQUIRED
INSTRUMENT GROUNDING:	PROVIDE PER MANUFACTURER
3. MANUFACTURER:	
A. ENDRESS & HAUSER – PROMAG SERIES	
B. ABB – MAGMASTER SERIES	
C. EMCO – MAGFLO SERIES	
D. BAILEY, FISCHER + PORTER – 10DX SERIES	
E. KROHNE – AQUAFLUX SERIES	

GENERAL FLOW METER TECHNICAL SPECIFICATION SHEET

FLOW METER TYPE: AVERAGING PITOT TUBE METER - D.P. TRANSMITTER (TYPE APFM-1)
SEE THE FLOW METER SCHEDULE FOR SPECIFIC TECHNICAL REQUIREMENTS.

1. GENERAL:	
PROVIDE AN AVERAGING PITOT TUBE ASSEMBLY COMPLETE WITH ALL AUXILIARY DEVICES WHICH MEETS ALL OF THE SERVICE CONDITIONS, FLOW PARAMETERS AND CALIBRATION REQUIREMENTS AS INDICATED. THE FLOW METER ASSEMBLY MATERIALS OF CONSTRUCTION SHALL BE FULLY COMPATIBLE WITH THE PROCESS FLUIDS AND THE AMBIENT CONDITIONS. PROVIDE ORIFICE SIZE AND D.P. RANGE CALCULATION SHEET.	
2. TECHNICAL:	
PROCESS FLUID:	AS SCHEDULED
MOUNTING:	1" NPT WELD-O-LET
TRANSMITTER:	1. ROSEMOUNT 3051S 2. ENDRESS & HAUSER – PMD70
3. MANUFACTURER:	
A. ROSEMOUNT 485 ANNUBAR	

GENERAL FLOW METER TECHNICAL SPECIFICATION SHEET

FLOW METER TYPE: THERMAL DISPERSION (TYPE TDFM-1)
SEE THE FLOW METER SCHEDULE FOR SPECIFIC TECHNICAL REQUIREMENTS.

1. GENERAL:	
PROVIDE A THERMAL DISPERSION FLOW METER ASSEMBLY COMPLETE WITH ALL AUXILIARY DEVICES, WHICH MEETS ALL OF THE SERVICE CONDITIONS, FLOW PARAMETERS AND CALIBRATION REQUIREMENTS AS INDICATED. THE FLOW METER ASSEMBLY MATERIALS OF CONSTRUCTION SHALL BE FULLY COMPATIBLE WITH THE PROCESS FLUIDS AND THE AMBIENT CONDITIONS. PROVIDE A COMPLETE SPECIFICATION SHEET FOR EACH METER	
2. TECHNICAL:	
PROCESS FLUID:	AS SCHEDULED
METER TYPE:	THERMAL DISPERSION
MOUNTING:	3/4" NPT
PROCESS WETTED PARTS:	316 STAINLESS STEEL
MAXIMUM PRESSURE DROP:	0.1 PSI AT MAXIMUM DESIGN FLOW
ELECTRONICS HOUSINGS:	NEMA 4, FACTORY MUTUAL APPROVAL.
FLOW OUTPUT SIGNAL:	4 TO 20 mA DC LINEAR ANALOG RATE IN SCFM.
ACCURACY:	+/- 1% OF FULL SCALE.
REPEATABILITY:	+/- 1% OF FULL SCALE.
CALIBRATED RANGE:	AS SCHEDULED
POWER INPUT:	120 VAC, 60 HZ.
INSERTION LENGTH:	PROVIDE "U" LENGTH (PROCESS CONNECTION TO PROBE TIP) PER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
3. MANUFACTURER:	
A. FLUID COMPONENTS, INC. – MODEL ST98B-CA FLEX MASS	

END OF SECTION

Revision History	
Date	Rev. No.
A	0
B	0
C	0
D	0
E	0
F	0
02-19-09	0

AWW/djo [CV,EL,ME]

C:\d\timsdatasf\BROOKHAVEN_NATIONAL_LABORATORY\SF070003\200-PROJEXEC\280-SPEC\13865B1.doc